

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

LISTING SERVICE

LISTING NO. 7515-0531:108 Page 1 of 1

CATEGORY: Pipe/Fittings

LISTEE: Victaulic, PO Box 31, Easton PA 18044-0031
Contact: Mike John *(610) 559-3300 *Fax (610) 923-3095

DESIGN: Model 606 coupling and Model 641 grooved to flanged adaptors. Suitable for use in dry pipe systems for temperatures to -40°F. Refer to listee's data sheet for detailed product description and operational considerations.

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes and ordinances and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name, model number, year of manufacture, size and UL label.

APPROVAL: Listed as rubber gasket fittings for use with roll-grooved Types K and L cooper pipe.

NOTE: Formerly 7550-0531:108

*Rev. 08-21-2003



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued:

AUGUST 21, 2003

*Listing Expires **June 30, 2004***

Authorized By:

DIANE K. AREND, Senior Deputy
Program Manager